



		Must Be Defined										Options				
		V	2		-											
<u>Down Cable Connection</u>																
	7-Pin Amphenol Connector	07														
**	14-Pin Amphenol Connector	14														
	Internal Connecting Terminal Block	NT														
<u>Supply Voltage</u>																
	Single Phase 120 VAC	1														
	Three Phase 120 VAC	3														
<u>SCADA Communications</u>																
	None	0														
	Fiber with ST Connectors	F														
	Serial with DB-9 Connector	S														
(Phoenix Conn)	Serial Direct Hardwired	D														
<b>(Define if using PoE)</b>	Ethernet	E														
<u>Temperature Sensor</u>																
	None	0														
	Temp	T														
<u>Trip Operation Type</u>																
	AC Trip	A														
	DC Trip	D														
	AC and DC Trip	B														
<u>Current &amp; Voltage Sensing</u>																
	None	0														
(0-10V)	LPCS	L														
	CT	C														
**	(0-10V) LPCS	B														
	(0-148V) PT	PT														
<u>Cap Bank Wye Neutral Sensing</u>																
	None	0														
	CT	C														
(120V NOM Secondary)	PT	P														
<u>Enclosure</u>																
	12x14 Carlon w/ Meter Base	0														
(NMK12V)	12x14 Carlon w/ Carlon Brackets	1														
(VBK01)	12x14 Carlon w/ Aluminum Brackets	2														
<u>Compatible with:</u>																
		DC Trip														
Cooper ECS	Type 1	1														
Joslyn VSV	Type 2	2														
Cooper VCS-1S																
Maysteel UltraVac																
<u>Backup Power</u>																
	Last Gasp	0														
	Extended Last Gasp	1														
(12V DC)	Battery & Charger	2														
<u>Options - Not Required</u>																
		(Dash)														
		-														
<u>Radio Part Number</u>																
	Freewave FGR2-PE-U	R1														
	Freewave FGR09CSU	R2														
	GE MDS SDx	R3														
	<b>(User Specified Radio)</b>	R0														
<u>Isolation Power Supply</u>																
	12 VDC	E1														
(Radio or PoE)	24 VDC	E2														
	48 VDC	E4														
	IEEE 802.3af	E0														
<u>Staged Banks</u>																
	Configuration 1	21														
	Configuration 2	22														

\*\* Three Phase VAr-Min ONLY